

Combustible Decorations are prohibited in

any health care occupancy, unless one of the following criteria is met:

- 1) They are flame-retardant or are treated with approved fire-retardant coating that is listed and labeled for application to the material to which it is applied.
- 2) The decorations meet the requirements of NFPA 701.
- 3) The decorations exhibit a heat release rate not exceeding 100 kW when tested in accordance with NFPA 289.
- 4) *The decorations, such as photographs, paintings, and other art, are attached directly to the walls, ceiling, and non-fire-rated doors in accordance with the following:
 - a) Decorations on non-fire-rated doors do not interfere with the operation or any required latching of the door and do not exceed the area limitations of 19.7.5.6(b), (c), or (d).
 - b) Decorations do not exceed 20 percent of the wall, ceiling, and door areas inside any room or space of a smoke compartment that is not protected throughout by an approved automatic sprinkler system
 - c) Decorations do not exceed 30 percent of the wall, ceiling, and door areas inside any room or space of a smoke compartment that is protected throughout by an approved supervised automatic sprinkler system.
 - d) Decorations do not exceed 50 percent of the wall, ceiling, and door areas inside patient sleeping rooms, having a capacity not exceeding four persons, in a smoke compartment that is protected throughout by an approved, supervised automatic sprinkler system.
- 5) *They are decorations, such as photographs and paintings, in such limited quantities that a hazard of fire development or spread is not present



Live Christmas trees are prohibited in health care occupancies!





Temporary Holiday Lighting

Temporary lighting installations shall be permitted for a period not to exceed 90 days for holiday decorative lighting.

Warning: Combustible Decorations shall not be displayed on Fire Rated doors.



Office of the State Fire Marshal